



Pete K. Rahn, Director

---

**ADDENDUM 001  
REQUEST FOR BID  
D611-008-RW Demolition Route 185**

Bidders shall acknowledge receipt of Addendum 001 (ONE) by signing and including it with original quote. The due date for receipt of this bid **does not change** by this Addendum. Accordingly, the following clarifications, questions and answers are believed to be of general interest to all potential bidders. All other terms and conditions remain unchanged and in full force.

Name and Title of Signer (Print or type)	Name and Title of Department Authority  Terri Mount Sr. General Services Specialist
Bidder Signature	Department of Transportation  <i>Terri Mount</i>
Signature of person authorized to sign	Authorizing Signature
Date Signed:	Date Signed: 07/15/10

**Bidder Question 1.** Are there any tanks to be removed? (Gas, oil, or septic)

**MoDOT Response 1.** The bid items list all work required. There is a septic tank but no other tanks.

**Bidder Question 2.** Are there any utilities that need to be capped off as per city or state specs that we should include in the bid?

**MoDOT Response 2.** Sewer for the building is a septic system - see question 1. Water is being disconnected by the Village of Oak Grove - see Section 9.0 of Exhibit C for details.

**Bidder Question 3.** Is there any asbestos inside of building? If so, does asbestos testing need to be done as well?

**MoDOT Response 3.** See Exhibit D, Asbestos and Heavy Metals Survey Report, for asbestos survey details of the entire building. Also see section 8.0 of Exhibit C for details about proper handling and disposal of non-friable asbestos containing roofing materials.

**THIS ADDENDUM MUST BE SIGNED AND SUBMITTED WITH RESPONSE.**

